

	<p style="text-align: center;">DICHIARAZIONE DI CONFORMITA'</p> <p style="text-align: center;">CE</p> <p style="text-align: center;">DECLARATION OF CONFORMITY</p>	<div style="display: flex; justify-content: space-around;">   </div> <p style="text-align: center;">ISO 9001:2008 Certificato SQS n° 36383 IQNET n° CH-36383</p> <p style="text-align: center;">Pag. 1/2</p>
---	---	--

COSTER GROUP s.r.l.

con sede in Peschiera Borromeo (MI) via Giuseppe di Vittorio, 24
based in Milan - Peschiera Borromeo (MI) via Giuseppe di Vittorio, 24
 Tel: +39.02.2722121
 E-Mail: info@costergroup.eu
<http://www.costergroup.eu>

Alleghiamo dichiarazione di conformità relativa a:

- Alimentatore barra DIN 12V-10W mod. **HDR 15** corrispondente sigla Coster **ALM 1210**

Here attached please find the declaration of conformity for the following product:

- DIN rail 12V-10W power supply unit code **HDR 15** corresponding to Coster code **ALM 1210**

COSTER GROUP s.r.l.



Declaration of Conformity

For the following equipment :

Product Name: Din Rail Switching Power Supply

Model Designation: HDR-15-x (x=5,12,15,24,48)

is herewith confirmed to comply with the requirements set out in the Council Directive, the following standards were applied :

RoHS Directive (2011/65/EU)

Low Voltage Directive (2014/35/EU) :

EN60950-1:2006+A11:2009+A1:2010+A12:2011+A2:2013
EN61558-1:2005+A1/EN61558-2-16:2009+A1

CB certificate No : DK-59187-UL
TUV certificate No : R50360933

Electromagnetic Compatibility Directive (2014/30/EU) :

EMI (Electro-Magnetic Interference)

Conducted emission / Radiated emission

	EN55032:2015	Class B
Harmonic current	EN61000-3-2:2014	
Voltage flicker	EN61000-3-3:2013	

EMS (Electro-Magnetic Susceptibility)

EN55024:2010+A1:2015	EN61000-6-2:2005		
ESD air	EN61000-4-2:2009	Level 3	8KV
ESD contact	EN61000-4-2:2009	Level 2	4KV
RF field susceptibility	EN61000-4-3:2006+A1:2008+A2:2010	Level 3	10V/m
EFT bursts	EN61000-4-4:2012	Level 3	2KV/5KHz
Surge susceptibility	EN61000-4-5:2014	Level 4	2KV/Line-Line
Conducted susceptibility	EN61000-4-6:2014	Level 3	10V
Magnetic field immunity	EN61000-4-8:2010	Level 4	30A/m
Voltage dip, interruption	EN61000-4-11:2004	>95% dip 0.5 periods 30% dip 25 periods >95% interruptions 250 periods	

Note:

A component power supply with load will be installed into final equipment which consists of an electronically shielded metal enclosure. Since EMC performance will be affected by the complete installation, the final equipment manufacturers must re-qualify EMC Directive on the complete installation again.

The EMC tests mentioned above are performed using a well defined metal plate to simulate said metal enclosure.

For guidance on how to perform these EMC tests, please refer to "EMI testing of component power supplies".(as available on <http://www.meanwell.com>)" and TDF (Technical Documentation File).

This Declaration is effective from serial number EB8xxxxxx

Person responsible for marking this declaration :

MEAN WELL Enterprises Co., Ltd.

(Manufacturer Name)

No.28, Wuquan 3rd Rd., Wugu Dist., New Taipei City 248, Taiwan

(Manufacturer Address)

Johnny Huang/Manager, Certification Center :

(Name / Position)

(Signature)

Alex Tsai/Director, Marketing Department :

(Name / Position)

(Signature)

Taiwan

(Place)

Feb. 1st, 2018

(Date)