




<p>c o s t e  g r o u p</p>	<p>DICHIARAZIONE DI CONFORMITA'</p> <p>CE</p> <p>DECLARATION OF CONFORMITY</p>	<div style="display: flex; justify-content: space-around;">   </div> <p>ISO 9001:2008 Certificato SQS n° 36383 IQNET n° CH-36383</p> <p>Pag. 1/2</p>
--	---	--

COSTER GROUP s.r.l.

con sede legale in Milano via San G.B. De La Salle 4/A,
based in Milan - Via S.G.B. De La Salle 4/a
Tel: +39.02.2722121, Fax: +39.02.2593645
E-Mail: info@costergroup.eu
<http://www.costergroup.eu>

Alleghiamo dichiarazione di conformità relativa a:

- Valvola ad otturatore mod. **VL3 - VLN3** corrispondente sigla Coster **VL3 - VLN3**

Here attached please find the declaration of conformity for the following product:

- Seat Valve code **VL3 – VLN3** corresponding to Coster code **VL3 – VLN3**

COSTER GROUP s.r.l.

EU-DECLARATION OF CONFORMITY

Danfoss A/S
Business Segment Heating & Water
District Heating Controls
DK-6430 Nordborg, Denmark

declares under sole responsibility that the product types:

2- and 3- way seated valve

VL 2 PN 6, DN 15 – 100
VL 3 PN 6, DN 15 – 100

to which this declaration relates, are in conformity with the following directives, provided that they are used according to our instructions.

PED-directive 97/23/EEC

PN (PS)	DN<= 32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250
6	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A
10	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A
16	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H
25	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H	Cat. II module H	Cat. III module H
40	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H	Cat. II module H	Cat. III module H	Cat. III module H	Cat. III module H

Conformity assessment procedures according to PED - Annex III.

Bureau Veritas (0062) will currently conduct inspection.

Products according to PED - Article 3 §3 are not CE-marked.

NORDBORG, 2004-02-23
Place and date of issue:


Signature, Quality Manager