

  CONTROLLI TEMPERATURA ENERGIA	DICHIARAZIONE DI CONFORMITA'  DECLARATION OF CONFORMITY	  ISO 9001:2008 Certificato SQS n° 36383 IQNET n° CH-36383 <hr/> Pag. 1/2
---	--	---

COSTER T.E. S.p.A.

con sede legale in Milano via San G.B. De La Salle 4/A,
based in Milan - Via S.G.B. De La Salle 4/a
 Tel: +39.02.2722121, Fax: +39.02.2593645
 E-Mail: info@coster.eu
<http://www.coster.eu>

Alleghiamo dichiarazione di conformità relativa a:

- Valvola ad otturatore mod. **VM 2/VB 2** corrispondente sigla Coster **VM 2../VB 2..**

Here attached please find the Declaration of conformity for the following product:

- Seat Valve code **VM 2/VB 2** corresponding to Coster code **VM 2../VB 2..**

COSTER T.E. S.p.A.

EU-DECLARATION OF CONFORMITY

Danfoss A/S
Heating Division
Danfoss District Heating
DK-6430 Nordborg, Denmark

declares under sole responsibility that the product types:

2-way pressure balanced valves
VB 2 PN 25, DN 15 - 50
VM 2 PN 25, DN 15 - 50

to which this declaration relates, are in conformity with the following directives, provided that they are used according to our instructions.

PED-directive 97/23/EEC

PN (PS)	DN<= 32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250	DN 300
6	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module H	Cat. I module H	Cat. I module H
10	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H
16	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. II module H	Cat. II module H
25	Art. 3§3	Art. 3§3	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. II module H	Cat. II module H	Cat. III module H	Cat. III module H
40	Art. 3§3	Cat. I module H	Cat. I module H	Cat. I module H	Cat. I module H	Cat. II module H	Cat. II module H	Cat. III module H	Cat. III module H	Cat. III module H	Cat. III module H

Conformity assessment procedures according to PED - Annex III.

Bureau Veritas (0041 will currently conduct inspection.

Products according to PED - Article 3 §3 are not CE-marked.

NORDBORG, 5/2-2007
 Place and date of issue


 Signature, Quality Director