

  CONTROLLI TEMPERATURA ENERGIA	DICHIARAZIONE DI CONFORMITA'  DECLARATION OF CONFORMITY	  ISO 9001:2008 Certificato SQS n° 36383 IQNET n° CH-36383 <hr/> Pag. 1/2
--	--	---

COSTER T.E. S.p.A.

con sede legale in Milano via San G.B. De La Salle 4/A,
 based in Milan - Via S.G.B. De La Salle 4/a
 Tel: +39.02.2722121, Fax: +39.02.2593645
 E-Mail: info@coster.eu
<http://www.coster.eu>

Alleghiamo dichiarazione di conformità relativa a:

- Valvola ad otturatore mod. **VF3 - VRB3 - VRG3** corrispondente
 sigla Coster **VF 3.. – VFN 3.. – VRBN 3.. – VRGN 3..**

Here attached please find the declaration of conformity for the following product:

- Seat Valve code **VF3 – VRB3 –VRG3** corresponding to Coster code
VF 3.. - VFN 3 –VRBN 3.. – VRGN 3..

COSTER T.E. S.p.A.

EU-DECLARATION OF CONFORMITY

Danfoss A/S
Heating Division
Danfoss District Heating
DK-6430 Nordborg, Denmark

declares under sole responsibility that the product types:

2- and 3-way seated valves

VF 2	PN 16, DN 15 - 150
VF 3	PN 16, DN 15 - 150
VFS 2	PN 25, DN 15 - 100
VRB 3	PN 16, DN 15 - 50
VRG 3	PN 16, DN 15 - 50

to which this declaration relates, are in conformity with the following directives, provided that they are used according to our instructions.

PED-directive 97/23/EEC

PN (PS)	DN<= 32	DN 40	DN 50	DN 65	DN 80	DN 100	DN 125	DN 150	DN 200	DN 250
6	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A
10	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A
16	Art. 3§3	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H
25	Art. 3§3	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H	Cat. II module H	Cat. III module H
40	Art. 3§3	Cat. I module A	Cat. I module A	Cat. I module A	Cat. I module A	Cat. II module H	Cat. II module H	Cat. III module H	Cat. III module H	Cat. III module H

Conformity assessment procedures according to PED - Annex III.
Bureau Veritas (0041) will currently conduct inspection.
 Products according to PED - Article 3 §3 are not CE-marked.

NORDBORG, 12/6-2009
 Place and date of issue


 Signature, Quality Director